



NOTE: THIS SKETCH IS A NON-PROPRIETARY GRAPHIC REPRESENTATION OF A LUMINAIRE THAT MAY MEET THE SPECIFICATION REQUIREMENTS. IT IS NOT INTENDED TO INDICATE A CERTAIN MANUFACTURER OR PREFERENCE.

LUMINAIRE REQUIREMENTS:

1. HOUSING – HIGH-IMPACT, UV-STABILIZED, INJECTION-MOLDED THERMOPLASTIC HOUSING.
2. LIGHT SOURCE – SOLID STATE LEDS.
3. DRIVER – INTEGRAL, HIGH-EFFICIENCY DRIVER WITH MINIMUM 0.9 PF, OPERATING VOLTAGE OF 120-277V, THERMAL MANAGEMENT, AND < 20% THD. ON/OFF CONTROL AND BATTERY BACKUP INTEGRAL TO UNIT.
4. CERTIFICATION – NFPA 101. UL LISTED FOR DAMP OR WET LOCATION, ROHS COMPLIANT. COMPLIES WITH IES LM79, LM80 AND TM21 TESTING STANDARDS.
5. MOUNTING – WALL SURFACE MOUNTED.
6. OPTIONS – WHITE OR BLACK FINISH.

LED EMERGENCY LIGHTING UNIT (ELU)

REVISED:

NOVEMBER 2020

LIGHTING PLATE:

NL-26