



NOTE 1: PROVIDE ONE 1-INCH SPARE CONDUIT STUBBED-OUT FIVE FEET FROM PAD. COORDINATE WITH ACTIVITY FOR ADDITIONAL METERING INPUT (GAS, STEAM OR WATER SYSTEMS).

NOTE 2: PROVIDE THE COMM CIRCUIT TO THE MECHANICAL/ELECTRICAL EQUIPMENT ROOM. COORDINATE WITH ACTIVITY.

## PAD-MOUNTED TRANSFORMER DETAIL

NOT TO SCALE

[ MULTI-GROUNDED PRIMARY SYSTEM (DELTA-WYE) - WITH SURGE ARRESTERS ]