



NOTE 1: PROVIDE ONE 27mm SPARE CONDUIT STUBBED-OUT 1.5m FROM PAD.
COORDINATE WITH ACTIVITY FOR ADDITIONAL METERING INPUT (GAS, STEAM OR WATER SYSTEMS).

NOTE 2: PROVIDE THE COMM CIRCUIT TO THE MECHANICAL/ELECTRICAL EQUIPMENT ROOM. COORDINATE WITH ACTIVITY.

PAD-MOUNTED TRANSFORMER DETAIL

NOT TO SCALE

[UNGROUNDED OR SINGLE GROUNDED PRIMARY SYSTEM – WITHOUT SURGE ARRESTERS]